



CERTIFICATE NUMBER
17-SQ1597461-PDA

DATE
25 Jan 2017

ABS TECHNICAL OFFICE
CN Shanghai ESD

CERTIFICATE OF DESIGN ASSESSMENT

This is to certify that a representative of this Bureau did, at the request of
TOP HI-TECH CO., LTD.

assess design plans and data for the below listed product. This assessment is a representation by the Bureau as to the degree of compliance the design exhibits with applicable sections of the Rules. This assessment does not waive unit certification or classification procedures required by ABS Rules for products to be installed in ABS classed vessels or facilities. This certificate, by itself, does not reflect that the product is Type Approved. The scope and limitations of this assessment are detailed on the pages attached to this certificate.

Product: **Lighting Fixtures, LED**

Model: **EX-THT-L1217, EX-THT-P1202**


This Product Design Assessment (PDA) Certificate 17-SQ1597461-PDA, dated 25/Jan/2017 remains valid until 24/Jan/2022 or until the Rules or specifications used in the assessment are revised (whichever occurs first).

This PDA is intended for a product to be installed on an ABS classed vessel, MODU or facility which is in existence or under contract for construction on the date of the ABS Rules or specifications used to evaluate the Product.

Use of the Product on an ABS classed vessel, MODU or facility which is contracted after the validity date of the ABS Rules and specifications used to evaluate the Product, will require re-evaluation of the PDA.

Use of the Product for non ABS classed vessels, MODUs or facilities is to be to an agreement between the manufacturer and intended client.

AMERICAN BUREAU OF SHIPPING


Bin-Hong Wang
Manager

NOTE: This certificate evidences compliance with one or more of the Rules, Guides, standards or other criteria of ABS or a statutory, industrial or manufacturer's standards. It is issued solely for the use of ABS, its committees, its clients or other authorized entities. Any significant changes to the aforementioned product without approval from ABS will result in this certificate becoming null and void. This certificate is governed by the terms and conditions as contained in ABS Rules 1-1-A3/5.9 Terms and Conditions of the Request for Product Type Approval and Agreement (2010).

TOP HI-TECH CO.

5F, NO.113, ZHONGCHENG ROAD

TUCHENG DISTRICT

NEW TAIPEI CITY

Taiwan, R.O.C. 236

Telephone: +886-2-2268-9570

Fax: +886-2-2268-9571

Email: sales@tht-ex.com

Web: www.tht-ex.com

Tier: 3 - Type Approved, unit certification not required

Product: Lighting Fixtures, LED**Model:** EX-THT-L1217, EX-THT-P1202**Intended Service:**

Lighting in Marine and Offshore Platform Applications

Description:

LED Luminaires intended for use in hazardous area Zone 1, Zone 2, Zone 21 and Zone 22.

Rating:

Temperature Rating: -20 Deg. C ~ +40 Deg. C;

Humidity Rating: 65%RH ~ 100% RH;

Environment: Hazardous, Chemical Corrosive, Salty, Dusty;

Hazardous Area Classification: Zone 1, Zone 2, Zone 21 and Zone 22;

Voltage Rating: 24 Vac or 110 Vac or 220 Vac;

Frequency: 50/60 Hz;

Lighting Rating: EX-THT-L1217: 60W, 106W, 110W, 116W, 120W; EX-THT-P1202: 40W;

Hazardous Area Rating:

EX-THT-L1217: II 2 G Ex d IIB + H2 T6...T4 Gb and II 2 D Ex tb IIIC T105 Deg. C Db;

EX-THT-P1202: II 2 G Ex d IIB T5 Gb and II 2 D Ex tb IIIC T100 Deg. C Db.

Service Restriction:

Unit Certification is not required for this product. If the manufacturer or purchaser request an ABS Certificate for compliance with a specification or standard, the specification or standard, including inspection standards and tolerances, must be clearly defined.

Use Mixed Test. Also ATEX certified equipment is not to be installed in hazardous areas on U.S Vessels unless it can be proved to have been tested to the applicable IEC 60079 series standards by an independent laboratory accepted by the U.S Coast Guard. USCG notice 01-12 (February 7, 2012).

All electrical equipment intended for installation in hazardous areas are to be certified safe type based on the class of the hazardous area at its location of installation. Certificates in this regard are to be presented to the ABS Surveyor for verification on a case by case basis.

Unless specially directed by Administration, this approval is not to be construed as a substitute for flag Administration's approval.

The Manufacturer declared that these products absolutely do not be used in Zone 0.

Comments:

Installation in Hazardous Areas is to be in accordance with 4-8-4/27, 5C-1-7/31 of the 2014 Steel Vessel Rules and 4-3-3/9 of the 2014 Mobile Offshore Drilling Units Rules as applicable and Special Conditions for Safe Use on corresponding Hazardous Area certificates.

In order to safely operate in accordance with each of the operating instructions, the installation, inspection and maintenance of the device is to be carried out by experienced people who trained various explosion protection laws and regulations of safe operation (IEC / EN 60079-14 and IEC / EN 60079-17) and the general principles of classification of the regions. These persons should implement appropriate in-service training periodically, and has electrician (machine) certificate qualifications and the background about explosion safe. A copy of IEC / EN 60079-14 and IEC / EN 60079-17 are to be maintained on board for future use.

Electrical equipment is to be constructed of durable, flame-retardant, moisture resistant materials, which are not subject to deterioration in the marine environment and at the temperatures to which it is likely to be exposed.

Electrical equipment is to be designed such that current-carrying parts with potential to earth are protected against accidental contact.

The Manufacturer has provided a declaration about the control of, or the lack of Asbestos in this product.

TOP HI-TECH CO.

5F, NO.113, ZHONGCHENG ROAD

TUCHENG DISTRICT

NEW TAIPEI CITY

Taiwan, R.O.C. 236

Telephone: +886-2-2268-9570

Fax: +886-2-2268-9571

Email: sales@tht-ex.com

Web: www.tht-ex.com

Tier: 3 - Type Approved, unit certification not required

Notes/Drawing/Documentation:

Drawing No. Correspondence, TOP HI-TECH DECLARATION, Revision: 0, Pages: 1
Drawing No. Correspondence, TOP HI-TECH FEE CONFIRMATION, Revision: 0, Pages: 1
Drawing No. Correspondence, TOP HI-TECH PDA REQUEST, Revision: 0, Pages: 1
Drawing No. L1217, Approval Drawing, Revision: 0, Pages: 1
Drawing No. L1217-1, Operation Instruction, Revision: 0, Pages: 1
Drawing No. L1217-2, Test Report-1, 09-April-2015, Revision: 0, Pages: 1
Drawing No. L1217-3, Test Report-2, 09-April-2015, Revision: 0, Pages: 1
Drawing No. P12-02-2, Test Report-1, 22-May-2015, Revision: 0, Pages: 1
Drawing No. P1202, Approval Drawing, Revision: 0, Pages: 1
Drawing No. P1202-1, Operation Manual, Revision: 0, Pages: 1
Drawing No. P1202-3, Test Report-2, 22-May-2015, Revision: 0, Pages: 1

Terms of Validity:

This Product Design Assessment (PDA) Certificate 17-SQ1597461-PDA, dated 25/Jan/2017 remains valid until 24/Jan/2022 or until the Rules or specifications used in the assessment are revised (whichever occurs first).

This PDA is intended for a product to be installed on an ABS classed vessel, MODU or facility which is in existence or under contract for construction on the date of the ABS Rules or specifications used to evaluate the Product.

Use of the Product on an ABS classed vessel, MODU or facility which is contracted after the validity date of the ABS Rules and specifications used to evaluate the Product, will require re-evaluation of the PDA.

Use of the Product for non ABS classed vessels, MODUs or facilities is to be to an agreement between the manufacturer and intended client.

STANDARDS**ABS Rules:**

The Rules applicable to this assessment are covered to the following only:

- Steel Vessel Rules (2017): 1-1-4/7.7, 1-1-A3, 1-1-A4, 4-8-3/1.3, 4-8-3/1.7, 4-8-3/1.11.1, 4-8-3/13.3.2 and 5C3-7/3.7.3 ii);
- Steel Vessels Under 90M (295 Feet) in Length (2017): 1-1-4/7.7, 1-1-A3 and 1-1-A4, 4-6-3/3.17 and 4-6-3/11.1.1(a);
- Offshore Support Vessels (2017): 1-1-4/7.7, 1-1-A3, 1-1-A4, 4-8-3/1.3, 4-8-3/1.7, 4-8-3/1.11.1 and 4-8-3/13.3.2;
- Facilities on Offshore Installations (2017): 1-1-4/7.7, 1-1-A2 and 1-1-A3;
- Mobile Offshore Drilling Unit Rules (2017): 1-1-4/7.7, 1-1-A2, 1-1-A3, 4-3-1/15, 4-3-3/3.1.1(a), 4-3-3/3.17, 4-3-3/9.1.2(b) and 4-3-3/9.1.2(c)

National:

British Standard BS EN 60079-0: 2011-06, EN 60079-1: 2007-04 and EN 60079-31: 2013-11

International:

IEC 60079-0 Edition 6.0 2011-06; IEC 60079-1 Sixth edition 2007-04; IEC 60079-31 Edition 2.0 2013-11;

Government:

NA

TOP HI-TECH CO.

5F, NO.113, ZHONGCHENG ROAD

TUCHENG DISTRICT

NEW TAIPEI CITY

Taiwan, R.O.C. 236

Telephone: +886-2-2268-9570

Fax: +886-2-2268-9571

Email: sales@tht-ex.com

Web: www.tht-ex.com

Tier: 3 - Type Approved, unit certification not required

EUMED:

NA

OTHERS:

NA